

# Bridgeport Elementary

<u>Location Number</u>	<u>Description</u>	<u>Sample #</u>	<u>Sample Date</u>	<u>Results</u>	<u>Remediation</u>	<u>Retest Sample #</u>	<u>Retest Date</u>	<u>Retest Results</u>
1	Kitchen Sink East Wall	BP-1	4/8/16	.0082 mg/L				
2	Kitchen Sink Right North Wall	BP-2	4/8/16	.0066 mg/L				
3	Kitchen Sink Center North Wall	BP-3	4/8/16	.0075 mg/L				
4	Kitchen Sink Left North Wall	BP-4	4/8/16	.0051 mg/L				
5	Kitchen Bath Hand Sink	BP2-5	9/28/16	.022 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-5	3/17/17	.014 mg/L
6	Kitchen Custodial Sink	BP2-6	9/28/16	.033 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-6	3/17/17	.011 mg/L
7	Room 125 Hand Sink	BP2-7	9/28/16	.023 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-7	3/17/17	.020 mg/L
8	Room 126 Hand Sink	BP2-8	9/28/16	.0076 mg/L				
9	Main Entrance Water Fountain Right	BP-5	4/8/16	.0036 mg/L				
10	Main Entrance Water Fountain Left	BP-6	4/8/16	.0036 mg/L				
11	Boys Bath Hand Sink (Left)	BP2-11	9/28/16	<.0010 mg/L				
12	Girls Bath Hand Sink (Right)	BP2-12	9/28/16	<.0010 mg/L				
13	Main Office Hand Sink	BP-7	4/8/16	.0030 mg/L				
14	Principal Bath Hand Sink	BP2-14	9/28/16	.012 mg/L				
15	Room 102 Bath Hand Sink	BP2-15	9/28/16	.0036 mg/L				
16	Room 102 Hand Sink	BP2-16	9/28/16	.0038 mg/L				
17	Room 102 Water Fountain	BP-8	4/8/16	.0026 mg/L				
18	Room 108 Nurses Office Hand Sink	BP-9	4/8/16	.0043 mg/L				
19	Nurses Office Bath Hand Sink	BP2-19	9/28/16	<.0010 mg/L				
20	Room 104 Bath Hand Sink	BP2-20	9/28/16	.0054 mg/L				
21	Room 104 Hand Sink	BP2-21	9/28/16	.0028 mg/L				
22	Room 104 Water Fountain	BP-10	4/8/16	.0037 mg/L				
23	Fourth Grade Custodial Sink	BP2-23	9/28/16	.0055 mg/L				
24	Room 103 Bath Hand Sink	BP2-24	9/28/16	.0041 mg/L				
25	Room 103 Hand Sink	BP2-25	9/28/16	.0032 mg/L				
26	Room 103 Water Fountain	BP-11	4/8/16	.0040 mg/L				
27	Library Hand Sink	BP2-27	9/28/16	.0045 mg/L				
28	Library Bath Hand Sink	BP2-28	9/28/16	.0098 mg/L				
29	Library Hall Water Fountain	BP-12	4/8/16	.005 mg/L				
30	Room 130 Bath Hand Sink	BP2-30	9/28/16	.0049 mg/L				
31	Room 133 Bath Hand Sink	BP2-31	9/28/16	.0032 mg/L				
32	Room 133 Counter Hand Sink(Hallway)	BP2-32	9/28/16	.0010 mg/L				
33	Room 133 Counter Hand Sink (Window)	BP2-33	9/28/16	<.0010 mg/L				
34	Room 122/105 Bath Hand Sink	BP2-34	9/28/16	.020 mg/L	Posted Non-Potable, Replace fixture, Retest	BP23-34	3/17/17	.006 mg/L
35	Room 105 Water Fountain	BP-14	4/8/16	.0028 mg/L				
36	Room 105 Hand Sink	BP2-36	9/28/16	.0039 mg/L				
37	Room 105/106 Bath Hand Sink	BP2-37	9/28/16	.0038 mg/L				
38	Room 134 Water Fountain	BP-13	4/8/16	.0030 mg/L				
39	Room 134 Hand Sink	BP2-39	9/28/16	.0037 mg/L				
40	Room 134/107 Bath Hand Sink	BP2-40	9/28/16	.0041 mg/L				
41	Room 107 Water Fountain	BP-15	4/8/16	.0049 mg/L				
42	Room 107 Hand Sink	BP2-42	9/28/16	.014 mg/L				
43	Room 107 Bath Hand Sink	BP2-43	9/28/16	.024 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-43	3/17/17	.0082 mg/L
44	Room 106 Water Fountain	BP-16	4/8/16	.0042 mg/L				
45	Room 106 Hand Sink	BP2-45	9/28/16	.026 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-45	3/17/17	.0027 mg/L
46	Room 106 Bath Hand Sink	BP2-46	9/28/16	.0040 mg/L				
47	Room 113 Hand Sink	BP2-47	9/28/16	.0016 mg/L				
48	Room 113 Water Fountain	BP-22	4/8/16	.0043 mg/L				
49	Room 114 Hand Sink	BP2-49	9/28/16	.0012 mg/L				
50	Room 114 Water Fountain	BP-20	4/8/16	.0017 mg/L				
51	Room 101 Hand Sink	BP-18	4/8/16	.0013 mg/L				
52	Room 101 Bath Hand Sink	BP2-52	9/28/16	.0018 mg/L				
53	Room 120 Bath Hand Sink	BP2-53	9/28/16	.0036 mg/L				
54	Room 120 Hand Sink	BP2-54	9/28/16	.0080 mg/L				

# Bridgeport Elementary

55	Room 120 Water Fountain	BP-17	4/8/16	.0031 mg/L				
56	Room 121 Water Fountain	BP-19	4/8/16	<.0010 mg/L				
57	Room 121 Hand Sink	BP2-57	9/28/16	<.0010 mg/L				
58	Room 128 Hand Sink	BP2-58	9/28/16	<.0010 mg/L				
59	Room 128 Water Fountain	BP-21	4/8/16	.0038 mg/L				
60	Room 119 Water Fountain	BP-23	4/8/16	<.0010 mg/L				
61	Room 119 Hand Sink	BP2-61	9/28/16	.015 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-621	3/17/17	.0012 mg/L
62	Room 112 Hand Sink	BP2-62	9/28/16	.0011 mg/L				
63	Room 112 Water Fountain	BP-25	4/8/16	.0031 mg/L				
64	Room 118 Water Fountain	BP-24	4/8/16	.0014 mg/L				
65	Room 118 Hand Sink	BP2-65	9/28/16	.0012 mg/L				
66	Room 117 Water Fountain	BP-26	4/8/16	.0021 mg/L				
67	Room 117 Hand Sink	BP2-67	9/28/16	.0011 mg/L				
68	Room 111 Hand Sink	BP2-68	9/28/16	.0079 mg/L				
69	Room 111 Water Fountain	BP-27	4/8/16	.0030 mg/L				
70	Room 116 Water Fountain	BP-28	4/8/16	<.0010 mg/L				
71	Room 116 Hand Sink	BP2-71	9/28/16	.0027 mg/L				
72	Room 110 Hand Sink	BP2-72	9/28/16	.0054 mg/L				
73	Room 110 Hot Water Supply	BP-29	4/8/16	.0068 mg/L				
74	Room 123 Hand Sink	BP2-74	9/28/16	.0084 mg/L				
75	Gym Hall Water Fountain	BP-31	4/8/16	.0040 mg/L				
76	Room 115 Hand Sink	BP2-76	9/28/16	.014 mg/L				
77	Room 115 Water Fountain	BP-32	4/8/16	.0040 mg/L				
78	Boys Locker Left Hand Sink	BP2-78	9/28/16	.018 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-78	3/17/17	.016 mg/L
79	Boys Locker Right Hand Sink	BP2-79	9/28/16	.0045 mg/L				
80	Boys Locker Water Fountain	BP-33	4/8/16	.024 mg/L	Disconnected power and water supply to fountain. No longer in service.			
81	PE Office Hand Sink	BP2-81	9/28/16	.010 mg/L				
82	Room 109 Left Water Fountain	BP-35	4/8/16	.0058 mg/L				
83	Room 109 Hand Sink (Center)	BP2-83	9/28/16	.0016 mg/L				
84	Room 109 Right Water Fountain	BP-30	4/8/16	<.0010 mg/L				
85	Room 109 Hand Sink (Right)	BP2-85	9/28/16	.0036 mg/L				
86	Custodial Closet Sink	BP2-86	9/28/16	.0021 mg/L				
87	Girls Locker Left Hand Sink	BP2-87	9/28/16	.0077 mg/L				
88	Girls Locker Right Hand Sink	BP2-88	9/28/16	.018 mg/L	Posted Non-Potable, Replace fixture, Retest	BP2-88	3/17/17	.019 mg/L
89	Girls Locker Water Fountain	BP-34	4/8/16	.014 mg/L	Disconnected power and water supply to fountain. No longer in service.			
90	Maint Office Custodial Sink	BP2-90	9/28/16	.0043 mg/L				