

# Bridgeport Elementary

<u>Location Number</u>	<u>Description</u>	<u>Sample #</u>	<u>Sample Date</u>	<u>Results</u>	<u>Remediation</u>	<u>Retest Sample #</u>	<u>Retest Date</u>	<u>Retest Results</u>
1	Kitchen Sink East Wall	BP-1	10/20/20	0.012 mg/L				
2	Kitchen Sink Right North Wall	BP-2	10/20/20	0.0074 mg/L				
3	Kitchen Sink Center North Wall	BP-3	10/20/20	0.012 mg/L				
4	Kitchen Sink Left North Wall	BP-4	10/20/20	0.015 mg/L	Temporarily removed from service, Replace fixture/supply lines/shutoff, Re	BP2-04	1/5/21	0.0019 mg/L
5	Kitchen Bath Hand Sink	BP-5	10/20/20	0.054 mg/L	Posted Non-Potable			
6	Kitchen Custodial Sink	BP-6	10/20/20	0.013 mg/L				
7	Room 106 Hand Sink	BP-7	10/20/20	0.022 mg/L	Posted Non-Potable			
8	Room 105 Hand Sink	BP-8	10/20/20	0.012 mg/L				
9	Main Entrance Water Fountain Right	BP-9	10/20/20	0.0017 mg/L				
10	Main Entrance Water Fountain Left	BP-10	10/20/20	0.0023 mg/L				
11	Boys Bath Hand Sink (Left)	BP-11	10/20/20	<0.0010 mg/L				
12	Girls Bath Hand Sink (Right)	BP-12	10/20/20	<0.0010 mg/L				
13	Main Office Hand Sink	BP-13	10/20/20	0.0054 mg/L				
14	Principal Bath Hand Sink	BP-14	10/20/20	0.012 mg/L				
15	Room 143 Bath Hand Sink	BP-15	10/20/20	0.0060 mg/L				
16	Room 143 Hand Sink	BP-16	10/20/20	0.071 mg/L	Posted Non-Potable	BP2-16	2/24/21	.0026 mg/L
17	Room 143 Water Fountain	BP-17	10/20/20	0.0031 mg/L				
18	Room 140 Nurses Office Hand Sink	BP-18	10/20/20	0.0057 mg/L				
19	Nurses Office Bath Hand Sink	BP-19	10/20/20	0.0016 mg/L				
20	Room 141 Bath Hand Sink	BP-20	10/20/20	0.0079 mg/L				
21	Room 141 Hand Sink	BP-21	10/20/20	0.0094 mg/L				
22	Room 141 Water Fountain	BP-22	10/20/20	0.0087 mg/L				
23	Fourth Grade Custodial Sink	BP-23	10/20/20	0.0069 mg/L				
24	Room 139 Bath Hand Sink	BP-24	10/20/20	0.013 mg/L				
25	Room 139 Hand Sink	BP-25	10/20/20	0.0042 mg/L				
26	Room 139 Water Fountain	BP-26	10/20/20	0.0081 mg/L				
27	Library Hand Sink	BP-27	10/20/20	0.0037 mg/L				
28	Library Bath Hand Sink	BP-28	10/20/20	0.0093 mg/L				
29	Library Hall Water Fountain	BP-29	10/20/20	0.0062 mg/L				
30	Room 130 Bath Hand Sink	BP-30	10/20/20	0.0067 mg/L				
31	Room 131 Bath Hand Sink	BP-31	10/20/20	0.0052 mg/L				
32	Room 131 Counter Hand Sink(Hallway)	BP-32	10/20/20	0.0063 mg/L				
33	Room 131 Counter Hand Sink(Window)	BP-33	10/20/20	0.0015 mg/L				
34	Room 132/134 Bath Hand Sink	BP-34	10/20/20	0.0062 mg/L				
35	Room 134 Water Fountain	BP-35	10/20/20	0.0018 mg/L				
36	Room 134 Hand Sink	BP-36	10/20/20	0.0021 mg/L				
37	Room 134/136 Bath Hand Sink	BP-37	10/20/20	0.0021 mg/L				
38	Room 133 Water Fountain	BP-38	10/20/20	0.0042 mg/L				
39	Room 133 Hand Sink	BP-39	10/20/20	0.0033 mg/L				
40	Room 133/135 Bath Hand Sink	BP-40	10/20/20	0.0023 mg/L				
41	Room 135 Water Fountain	BP-41	10/20/20	0.0048 mg/L				
42	Room 135 Hand Sink	BP-42	10/20/20	0.0047 mg/L				
43	Room 135 Bath Hand Sink	BP-43	10/20/20	0.0029 mg/L				
44	Room 136 Water Fountain	BP-44	10/20/20	0.017 mg/L	Temporarily removed from service, Replace fixture/supply lines/shutoff, Re	BP2-44	2/24/21	.0026 mg/L
45	Room 136 Hand Sink	BP-45	10/20/20	0.0013 mg/L				
46	Room 136 Bath Hand Sink	BP-46	10/20/20	0.0013 mg/L				
47	Room 122 Hand Sink	BP-47	10/20/20	0.0014 mg/L				
48	Room 122 Water Fountain	BP-48	10/20/20	0.0037 mg/L				
49	Room 124 Hand Sink	BP-49	10/20/20	0.0012 mg/L				
50	Room 124 Water Fountain	BP-50	10/20/20	<0.0010 mg/L				
51	Room 126 Hand Sink	BP-51	10/20/20	<0.0010 mg/L				
52	Room 126 Bath Hand Sink	BP-52	10/20/20	0.0011 mg/L				
53	Room 127 Bath Hand Sink	BP-53	10/20/20	0.0040 mg/L				
54	Room 127 Hand Sink	BP-54	10/20/20	0.0068 mg/L				
55	Room 127 Water Fountain	BP-55	10/20/20	0.0013 mg/L				
56	Room 125 Water Fountain	BP-56	10/20/20	0.0019 mg/L				
57	Room 125 Hand Sink	BP-57	10/20/20	<0.0010 mg/L				
58	Room 123 Hand Sink	BP-58	10/20/20	<0.0010 mg/L				

# Bridgeport Elementary

59	Room 123 Water Fountain	BP-59	10/20/20	0.0044 mg/L	
60	Room 121 Water Fountain	BP-60	10/20/20	0.0019 mg/L	
61	Room 121 Hand Sink	BP-61	10/20/20	<0.0010 mg/L	
62	Room 120 Hand Sink	BP-62	10/20/20	<0.0010 mg/L	
63	Room 120 Water Fountain	BP-63	10/20/20	0.0011 mg/L	
64	Room 119 Water Fountain	BP-64	10/20/20	0.0039 mg/L	
65	Room 119 Hand Sink	BP-65	10/20/20	<0.0010 mg/L	
66	Room 117 Water Fountain	BP-66	10/20/20	0.0053 mg/L	
67	Room 117 Hand Sink	BP-67	10/20/20	0.0013 mg/L	
68	Room 118 Hand Sink	BP-68	10/20/20	0.0041 mg/L	
69	Room 118 Water Fountain	BP-69	10/20/20	0.0032 mg/L	
70	Room 115 Water Fountain	BP-70	10/20/20	<0.0010 mg/L	
71	Room 115 Hand Sink	BP-71	10/20/20	0.0012 mg/L	
72	Room 116 Hand Sink	BP-72	10/20/20	0.0036 mg/L	
73	Room 116 Hot Water Supply	BP-73	10/20/20	<0.0010 mg/L	
74	Room 113 Hand Sink	BP-74	10/20/20	0.0056 mg/L	
75	Gym Hall Water Fountain	BP-75	10/20/20	0.0050 mg/L	
76	Room 112 Hand Sink	BP-76	10/20/20	0.0065 mg/L	
77	Room 112 Water Fountain	BP-77	10/20/20	0.0025 mg/L	
78	Boys Locker Left Hand Sink	BP-78	10/20/20	0.020 mg/L	Posted Non-Potable
79	Boys Locker Right Hand Sink	BP-79	10/20/20	0.011 mg/L	
80	PE Office Hand Sink	BP-80	10/20/20	0.0074 mg/L	
81	Room 108 Water Fountain	BP-81	10/20/20	0.0028 mg/L	
82	Room 108 Hand Sink	BP-82	10/20/20	0.011 mg/L	
83	Custodial Closet Sink	BP-83	10/20/20	0.0027 mg/L	
84	Girls Locker Left Hand Sink	BP-84	10/20/20	0.018 mg/L	Posted Non-Potable
85	Girls Locker Right Hand Sink	BP-85	10/20/20	0.028 mg/L	Posted Non-Potable
86	Maint Office Custodial Sink	BP-86	10/20/20	0.0061 mg/L	

# Bolivar Elementary

<u>Location Number</u>	<u>Description</u>	<u>Sample #</u>	<u>Sample Date</u>	<u>Results</u>	<u>Remediation</u>	<u>Retest Sam</u>	<u>Retest Date</u>	<u>Retest Results</u>
1	Kitchen Custodial Sink	BO-1	10/23/20	<0.0010 mg/L				
2	Kitchen Ice Maker	BO-2	10/23/20	0.0037 mg/L				
3	Kitchen Wash Sink	BO-3	10/23/20	<0.0010 mg/L				
4	Kitchen Hand Sink	BO-4	10/23/20	0.0030 mg/L				
5	Kitchen Prep Sink	BO-5	10/23/20	<0.0010 mg/L				
6	Soup Kettle Supply	BO-6	10/23/20	<0.0010 mg/L				
7	Kitchen Hand Sink	BO-7	10/23/20	0.0017 mg/L				
8	Kitchen Wash Sink (Right)	BO-8	10/23/20	0.0036 mg/L				
9	Kitchen Wash Sink (Left)	BO-9	10/23/20	0.0012 mg/L				
10	Cafeteria Water Fountain Right	BO-10	10/23/20	<0.0010 mg/L				
11	Cafeteria Water Fountain Left	BO-11	10/23/20	<0.0010 mg/L				
12	Cafeteria Bath Hand Sink	BO-12	10/23/20	<0.0010 mg/L				
13	Cafeteria Hallway Sink Bank (South)	BO-13	10/23/20	<0.0010 mg/L				
14	Cafeteria Hallway Sink Bank	BO-14	10/23/20	0.0015 mg/L				
15	Cafeteria Hallway Sink Bank	BO-15	10/23/20	<0.0010 mg/L				
16	Cafeteria Hallway Sink Bank	BO-16	10/23/20	<0.0010 mg/L				
17	Cafeteria Hallway Sink Bank	BO-17	10/23/20	0.0012 mg/L				
18	Cafeteria Hallway Sink Bank	BO-18	10/23/20	<0.0010 mg/L				
19	Cafeteria Hallway Sink Bank	BO-19	10/23/20	0.0011 mg/L				
20	Cafeteria Hallway Sink Bank	BO-20	10/23/20	<0.0010 mg/L				
21	Cafeteria Hallway Sink Bank	BO-21	10/23/20	0.0011 mg/L				
22	Cafeteria Hallway Sink Bank	BO-22	10/23/20	<0.0010 mg/L				
23	Cafeteria Hallway Sink Bank ( North)	BO-23	10/23/20	<0.0010 mg/L				
24	Receiving Room Custodial Sink	BO-24	10/23/20	0.0011 mg/L				
25	Faculty Hand Sink	BO-25	10/23/20	<0.0010 mg/L				
26	Faculty Bath Hand Sink	BO-26	10/23/20	<0.0010 mg/L				
27	Library Hand Sink	BO-27	10/23/20	0.0018 mg/L				
28	Library Hall Custodial Sink	BO-28	10/23/20	0.10 mg/L	Posted Non-Potable, Locked Closet			
29	Room 126B Water Fountain	BO-29	10/23/20	<0.0010 mg/L				
30	Room 126B Hand Sink	BO-30	10/23/20	0.0014 mg/L				
31	Room 127 South Wall Hand Sink	BO-31	10/23/20	0.0017 mg/L				
32	Room 127 Island Hand Sink (Hall)	BO-32	10/23/20	0.0020 mg/L				
33	Room 127 Island Hand Sink (Window)	BO-33	10/23/20	0.0017 mg/L				
34	Room 128A Hand Sink	BO-34	10/23/20	<0.0010 mg/L				
35	Room 128A Water Fountain	BO-35	10/23/20	<0.0010 mg/L				
36	Room 130 Water Fountain	BO-36	10/23/20	<0.0010 mg/L				
37	Room 130 Hand Sink	BO-37	10/23/20	0.0039 mg/L				
38	Room 131 Hand Sink	BO-38	10/23/20	<0.0010 mg/L				
39	Room 131 Water Fountain	BO-39	10/23/20	<0.0010 mg/L				
40	Second Grade Hall Custodial Sink	BO-40	10/23/20	0.0010 mg/L				
41	Room 135 Hand Sink	BO-41	10/23/20	0.0012 mg/L				
42	Room 135 Water Fountain	BO-42	10/23/20	0.0058 mg/L				
43	Room 133 Water Fountain	BO-43	10/23/20	0.014 mg/L				
44	Room 133 Hand Sink	BO-44	10/23/20	<0.0010 mg/L				
45	Ladies Bath Hand Sink	BO-45	10/23/20	0.0012 mg/L				
46	Mens Bath Hand Sink	BO-46	10/23/20	0.0014 mg/L				
47	Room 132 Hand Sink	BO-47	10/23/20	0.0025 mg/L				
48	Room 134 Water Fountain	BO-48	10/23/20	<0.0010 mg/L				
49	Room 134 Hand Sink	BO-49	10/23/20	<0.0010 mg/L				
50	Room 136 Hand Sink	BO-50	10/23/20	<0.0010 mg/L				
51	Room 136 Water Fountain	BO-51	10/23/20	0.020 mg/L	Temporarily removed from service, clean fixture/flush/shutoff, Retest	BO2-51	12/10/20	0.0028 mg/L
52	Room 137 Water Fountain	BO-52	10/23/20	<0.0010 mg/L				
53	Room 137 Hand Sink	BO-53	10/23/20	<0.0010 mg/L				
54	Room 138 Water Fountain	BO-54	10/23/20	<0.0010 mg/L				
55	Room 138 Hand Sink	BO-55	10/23/20	<0.0010 mg/L				
56	Room 139 Water Fountain	BO-56	10/23/20	<0.0010 mg/L				
57	Room 139 Hand Sink	BO-57	10/23/20	<0.0010 mg/L				
58	Room 140 Water Fountain	BO-58	10/23/20	<0.0010 mg/L				
59	Room 140 Hand Sink	BO-59	10/23/20	<0.0010 mg/L				
60	Room 141 Water Fountain	BO-60	10/23/20	<0.0010 mg/L				

# Bolivar Elementary

61	Room 141 Hand Sink	BO-61	10/23/20	<0.0010 mg/L				
62	Room 142 Water Fountain	BO-62	10/23/20	<0.0010 mg/L				
63	Room 142 Hand Sink	BO-63	10/23/20	<0.0010 mg/L				
64	Room 143 Water Fountain	BO-64	10/23/20	<0.0010 mg/L				
65	Room 143 Hand Sink	BO-65	10/23/20	<0.0010 mg/L				
66	Room 144 Water Fountain	BO-66	10/23/20	<0.0010 mg/L				
67	Room 144 Hand Sink	BO-67	10/23/20	<0.0010 mg/L				
68	Room 146 Hand Sink	BO-68	10/23/20	<0.0010 mg/L				
69	Room 146 Water Fountain	BO-69	10/23/20	<0.0010 mg/L				
70	Room 147 Water Fountain	BO-70	10/23/20	<0.0010 mg/L				
71	Room 147 Hand Sink	BO-71	10/23/20	0.0023 mg/L				
72	Room 149 Water Fountain	BO-72	10/23/20	<0.0010 mg/L				
73	Room 149 Hand Sink	BO-73	10/23/20	<0.0010 mg/L				
74	Room 148 Hand Sink	BO-74	10/23/20	<0.0010 mg/L				
75	Room 148 Water Fountain	BO-75	10/23/20	<0.0010 mg/L				
76	Room 151B Water Fountain	BO-76	10/23/20	<0.0010 mg/L				
77	Room 151B Hand Sink	BO-77	10/23/20	<0.0010 mg/L				
78	Room 150 Hand Sink	BO-78	10/23/20	0.0037 mg/L				
79	Room 150 Water Fountain	BO-79	10/23/20	<0.0010 mg/L				
80	Girls Bathroom Left Hand Sink	BO-80	10/23/20	<0.0010 mg/L				
81	Girls Bathroom Center Hand Sink	BO-81	10/23/20	<0.0010 mg/L				
82	Girls Bathroom Right Hand Sink	BO-82	10/23/20	<0.0010 mg/L				
83	Boys Bathroom Right Hand Sink	BO-83	10/23/20	<0.0010 mg/L				
84	Boys Bathroom Center Hand Sink	BO-84	10/23/20	<0.0010 mg/L				
85	Boys Bathroom Left Hand Sink	BO-85	10/23/20	<0.0010 mg/L				
86	Main Entrance Water Fountain	BO-86	10/23/20	<0.0010 mg/L				
87	Main Office Hand Sink	BO-87	10/23/20	<0.0010 mg/L				
88	Main Office Hall Bath Hand Sink	BO-88	10/23/20	<0.0010 mg/L				
89	Nurses Office Hand Sink	BO-89	10/23/20	<0.0010 mg/L				
90	Nurses Office Bath Hand Sink	BO-90	10/23/20	<0.0010 mg/L				
91	Kindergarten/First Hall Water Fountain	BO-91	10/23/20	<0.0010 mg/L				
92	Coaches Office Bath Hand Sink	BO-92	10/23/20	<0.0010 mg/L				
93	Kindergarten Hall Bath Hand Sink	BO-93	10/23/20	<0.0010 mg/L				
94	Kindergarten Hall Custodial Sink	BO-94	10/23/20	0.0011 mg/L				
95	Room 109A Hand Sink	BO-95	10/23/20	0.0021 mg/L				
96	Room 109A Water Fountain	BO-96	10/23/20	<0.0010 mg/L				
97	Room 108B Hand Sink	BO-97	10/23/20	<0.0010 mg/L				
98	Room 111 Water Fountain	BO-98	10/23/20	<0.0010 mg/L				
99	Room 111 Hand Sink	BO-99	10/23/20	<0.0010 mg/L				
100	Room 110 Hand Sink	BO-100	10/23/20	<0.0010 mg/L				
101	Room 110 Water Fountain	BO-101	10/23/20	<0.0010 mg/L				
102	Room 113 Water Fountain	BO-102	10/23/20	<0.0010 mg/L				
103	Room 113 Hand Sink	BO-103	10/23/20	0.0043 mg/L				
104	Room 112 Hand Sink	BO-104	10/23/20	0.0015 mg/L				
105	Room 112 Water Fountain	BO-105	10/23/20	<0.0010 mg/L				
106	Room 115 Hand Sink Right	BO-106	10/23/20	0.0021 mg/L				
107	Room 115 Hand Sink Left	BO-107	10/23/20	0.0040 mg/L				
108	Room 114 Hand Sink	BO-108	10/23/20	<0.0010 mg/L				
109	Room 114 Water Fountain	BO-109	10/23/20	<0.0010 mg/L				
110	Room 117 Hand Sink Left	BO-110	10/23/20	0.024 mg/L	Posted Non-Potable	BO2-110	12/10/20	0.0011 mg/L
111	Room 117 Hand Sink Right	BO-111	10/23/20	0.016 mg/L	Posted Non-Potable	BO2-111	12/10/20	<0.0010 mg/L
112	Room 116 Hand Sink Left	BO-112	10/23/20	0.0013 mg/L				
113	Room 116 Hand Sink Right	BO-113	10/23/20	0.0032 mg/L				
114	Room 119 Hand Sink Right	BO-114	10/23/20	0.014 mg/L				
115	Room 119 Hand Sink Left	BO-115	10/23/20	0.0091 mg/L				
116	Room 118 Hand Sink Right	BO-116	10/23/20	0.0049 mg/L				
117	Room 118 Hand Sink Left	BO-117	10/23/20	0.0028 mg/L				
118	Kindergarten Hall Water Fountain	BO-118	10/23/20	<0.0010 mg/L				
119	Room 105 Hand Sink	BO-119	10/23/20	<0.0010 mg/L				
120	Music Hall Water Fountain Right	BO-120	10/23/20	<0.0010 mg/L				
121	Music Hall Water Fountain Left	BO-121	10/23/20	<0.0010 mg/L				
122	Boys Bathroom Hand Sink	BO-122	10/23/20	<0.0010 mg/L				

# Bolivar Elementary

123	Girls Bathroom Hand Sink	BO-123	10/23/20	<0.0010 mg/L
124	Coaches Office Bath Hand Sink	BO-124	10/23/20	0.0020 mg/L
125	Gym Water Fountain (Right)	BO-125	10/23/20	<0.0010 mg/L
126	Gym Water Fountain (Left)	BO-126	10/23/20	<0.0010 mg/L
127	Womens Bath Hand Sink (Right)	BO-127	10/23/20	<0.0010 mg/L
128	Womens Bath Hand Sink (Left)	BO-128	10/23/20	0.0019 mg/L
129	Mens Bath Hand Sink (Left)	BO-129	10/23/20	0.0029 mg/L
130	Mens Bath Hand Sink (Right)	BO-130	10/23/20	0.0021 mg/L
131	Receiving Area Outside Hose Bib	BO-131	10/23/20	0.0055 mg/L
132	2nd Grade Addition Outside Hose Bib	BO-132	10/23/20	<0.0010 mg/L

# Middle School

<u>Location Number</u>	<u>Description</u>	<u>Sample #</u>	<u>Sample Date</u>	<u>Results</u>	<u>Remediation</u>	<u>Retest Sampl</u>	<u>Retest Date</u>	<u>Retest Results</u>
1	Kitchen Custodial Sink	MS-1	10/21/20	0.0064 mg/L				
2	Ice Maker	MS-2	10/21/20	0.039 mg/L	Temporarily removed from service, Replace filter, Retest	MS2-2	12/10/20	<0.0010 mg/L
3	Kitchen Hand Sink	MS-3	10/21/20	0.0014 mg/L				
4	Cook Sink North	MS-4	10/21/20	0.0024 mg/L				
5	Cook Sink South	MS-5	10/21/20	0.0051 mg/L				
6	Cook Sink Left	MS-6	10/21/20	0.014 mg/L				
7	Cook Sink Right	MS-7	10/21/20	0.027 mg/L	Temporarily removed from service, clean fixture/flush/shutoff, Retest	MS2-7	12/10/20	0.0026 mg/L
8	Kettle Nearest Office	MS-8	10/21/20	0.0054 mg/L				
9	Kettle Nearest Dishwasher	MS-9	10/21/20	0.0020 mg/L				
10	Cook Sink (Island)	MS10	10/21/20	0.0047 mg/L				
11	Kitchen Hand Sink	MS-11	10/21/20	0.0021 mg/L				
12	Food Service Bath Hand Sink	MS-12	10/21/20	0.0011 mg/L				
13	Faculty Room Sink	MS-13	10/21/20	0.0065 mg/L				
14	Cafeteria Water Fountain	MS-14	10/21/20	<0.0010 mg/L				
15	Boys Bath Hand Sink Left	MS-15	10/21/20	0.0062 mg/L				
16	Boys Bath Hand Sink Right	MS-16	10/21/20	0.0021 mg/L				
17	Girls Bath Hand Sink Left	MS-17	10/21/20	<0.0010 mg/L				
18	Girls Bath Hand Sink Right	MS-18	10/21/20	<0.0010 mg/L				
19	Cafeteria Hall Water Fountain	MS-19	10/21/20	<0.0010 mg/L				
20	Womens Bath Hand Sink	MS-20	10/21/20	0.0016 mg/L				
21	Mens Bath Hand Sink	MS-21	10/21/20	0.0021 mg/L				
22	Band Practice Room Hand Sink	MS-22	10/21/20	0.0073 mg/L				
23	Gym Hall Water Fountain North	MS-23	10/21/20	<0.0010 mg/L				
24	Boys Locker Hand Sink Right	MS-24	10/21/20	<0.0010 mg/L				
25	Boys Locker Hand Sink Left	MS-25	10/21/20	0.0061 mg/L				
26	Gym Custodial Sink	MS-26	10/21/20	0.0032 mg/L				
27	Gym Hall Water Fountain South	MS-27	10/21/20	<0.0010 mg/L				
28	Girls Locker Hand Sink Left	MS-28	10/21/20	0.0053 mg/L				
29	Girls Locker Hand Sink Right	MS-29	10/21/20	0.0017 mg/L				
30	Womens PE Office Bath Hand Sink	MS-30	10/21/20	<0.0010 mg/L				
31	Room 1211 Hand Sink North	MS-31	10/21/20	0.0023 mg/L				
32	Room 1211 Hand Sink Right	MS-32	10/21/20	0.0088 mg/L				
33	Room 1211 Hand Sink Left	MS-33	10/21/20	0.0058 mg/L				
34	Room 1211 Hand Sink East	MS-34	10/21/20	0.062 mg/L	Temporarily removed from service, clean fixture/flush/shutoff, Retest	MS2-34	12/10/20	0.0051 mg/L
35	Room 1209 Hand Sink West	MS-35	10/21/20	0.013 mg/L				
36	Room 1209 Hand Sink Right	MS-36	10/21/20	0.0076 mg/L				
37	Room 1209 Hand Sink Left	MS-37	10/21/20	0.0066 mg/L				
38	Room 1209 Hand Sink North	MS-38	10/21/20	0.010 mg/L				
39	Room 1208 Hand Sink North	MS-39	10/21/20	0.007 mg/L				
40	Room 1208 Island Hand Sink North	MS-40	10/21/20	0.0029 mg/L				
41	Room 1208 Island Hand Sink South	MS-41	10/21/20	0.0033 mg/L				
42	Room 1206 Island Hand Sink South	MS-42	10/21/20	0.0037 mg/L				
43	Room 1206 Island Hand Sink North	MS-43	10/21/20	0.0046 mg/L				
44	Room 1206 Hand Sink North	MS-44	10/21/20	0.0014 mg/L				
45	Board Room (small) Bath Hand Sink	MS-45	10/21/20	<0.0010 mg/L				
46	Board Room (large) Bath Hand Sink	MS-46	10/21/20	0.0032 mg/L				
47	Board Room Hand Sink	MS-47	10/21/20	0.0029 mg/L				
48	Special Needs Break Room Hand Sink	MS-48	10/21/20	0.006 mg/L				
49	District Office Bath Hand Sink	MS-49	10/21/20	0.014 mg/L				
50	Womens Bath Hand Sink	MS-50	10/21/20	0.0074 mg/L				
51	District Office Break Room Sink	MS-51	10/21/20	0.0011 mg/L				
52	Supt Office Bath Hand Sink	MS-52	10/21/20	0.0054 mg/L				
53	District Office Custodial Sink	MS-53	10/21/20	0.032 mg/L	Posted Non-Potable, Locked Closet			
54	Nurses Office Bath Hand Sink South	MS-54	10/21/20	<0.0010 mg/L				
55	Nurses Office Hand Sink	MS-55	10/21/20	0.0021 mg/L				
56	Nurses Office Bath Hand Sink North	MS-56	10/21/20	0.0048 mg/L				
57	Main Office Bath Hand Sink	MS-57	10/21/20	<0.0010 mg/L				
58	Library Hand Sink	MS-58	10/21/20	0.0013 mg/L				

# Middle School

59	Pod A Hall Water Fountain	MS-59	10/21/20	<0.0010 mg/L			
60	Pod A Boys Bath Hand Sink Right	MS-60	10/21/20	<0.0010 mg/L			
61	Pod A Boys Bath Hand Sink Left	MS-61	10/21/20	0.0065 mg/L			
62	Pod A Girls Bath Hand Sink Left	MS-62	10/21/20	<0.0010 mg/L			
63	Pod A Girls Bath Hand Sink Right	MS-63	10/21/20	0.0036 mg/L			
64	Pod A Custodial Sink	MS-64	10/21/20	0.0028 mg/L			
65	Room 1008 Bath Hand Sink	MS-65	10/21/20	0.0015 mg/L			
66	Room 1008/1007 Hand Sink	MS-66	10/21/20	0.0077 mg/L			
67	Science Hall Water Fountain	MS-67	10/21/20	0.0026 mg/L			
68	Room 1102 Island Sink	MS-68	10/21/20	0.020 mg/L	Posted Non-Potable		
69	Room 1102 Island Sink	MS-69	10/21/20	0.037 mg/L	Posted Non-Potable		
70	Room 1102 Island Sink	MS-70	10/21/20	0.0073 mg/L			
71	Room 1102 Island Sink	MS-71	10/21/20	0.008 mg/L			
72	Room 1102 Island Sink	MS-72	10/21/20	0.024 mg/L	Posted Non-Potable		
73	Room 1102 Island Sink	MS-73	10/21/20	0.011 mg/L			
74	Room 1102 Island Hand Sink (teacher)	MS-74	10/21/20	0.008 mg/L			
75	Room 1102/1103 Storage Hand Sink	MS-75	10/21/20	0.0044 mg/L			
76	Room 1103 Island Hand Sink (teacher)	MS-76	10/21/20	0.0023 mg/L			
77	Room 1103 Island Sink	MS-77	10/21/20	0.017 mg/L	Posted Non-Potable		
78	Room 1103 Island Sink	MS-78	10/21/20	0.0089 mg/L			
79	Room 1103 Island Sink	MS-79	10/21/20	0.0068 mg/L			
80	Room 1103 Island Sink	MS-80	10/21/20	0.008 mg/L			
81	Room 1103 Island Sink	MS-81	10/21/20	0.0082 mg/L			
82	Room 1103 Island Sink	MS-82	10/21/20	0.0095 mg/L			
83	Greenhouse Hand Sink (Inside of Room)	MS-83	10/21/20	0.0024 mg/L			
84	Greenhouse Hose Bib	MS-84	10/21/20	0.007 mg/L			
85	Maintenance Break Hand Sink	MS-85	10/21/20	<0.0010 mg/L			
86	Maintenance Bath Hand Sink	MS-86	10/21/20	<0.0010 mg/L			
87	Pod B Hall Water Fountain	MS-87	10/21/20	<0.0010 mg/L			
88	Pod B Girls Bath Hand Sink Left	MS-88	10/21/20	<0.0010 mg/L			
89	Pod B Girls Bath Hand Sink Right	MS-89	10/21/20	0.0016 mg/L			
90	Pod B Boys Bath Hand Sink Right	MS-90	10/21/20	0.0022 mg/L			
91	Pod B Boys Bath Hand Sink Left	MS-91	10/21/20	0.0032 mg/L			
92	Pod B Custodial Sink	MS-92	10/21/20	0.0015 mg/L			
93	Room 1112 Hand Sink Left	MS-93	10/21/20	0.026 mg/L	Temporarily removed from service, clean fixture/flush/shutoff, Retest	MS2-93	12/10/20 0.014 mg/L
94	Room 1112 Hand Sink Center	MS-94	10/21/20	0.019 mg/L	Temporarily removed from service, clean fixture/flush/shutoff, Retest	MS2-94	12/10/20 0.0091 mg/L
95	Room 1112 Hand Sink Right	MS-95	10/21/20	0.022 mg/L	Temporarily removed from service, clean fixture/flush/shutoff, Retest	MS2-95	12/10/20 0.014 mg/L
96	Room 2111 Storage Hand Sink	MS-96	10/21/20	0.027 mg/L	Posted Non-Potable		
97	Room 2110 Storage Hand Sink	MS-97	10/21/20	0.006 mg/L			
98	Pod B 2nd Floor Water Fountain	MS-98	10/21/20	<0.0010 mg/L			
99	Pod B Boys Bath Hand Sink Right	MS-99	10/21/20	<0.0010 mg/L			
100	Pod B Boys Bath Hand Sink Left	MS-100	10/21/20	0.0063 mg/L			
101	Pod B Girls Bath Hand Sink Left	MS-101	10/21/20	<0.0010 mg/L			
102	Pod B Girls Bath Hand Sink Right	MS-102	10/21/20	0.0042 mg/L			
103	Pod B 2nd Floor Custodial Sink	MS-103	10/21/20	0.0044 mg/L			
104	61 Wing Water Fountain	MS-104	10/21/20	0.0042 mg/L			
105	Faculty Bath Hand Sink	MS-105	10/21/20	<0.0010 mg/L			
106	Faculty Break Room Hand Sink	MS-106	10/21/20	0.0037 mg/L			
107	Room 2103 Island Sink	MS-107	10/21/20	0.0095 mg/L			
108	Room 2103 Island Sink	MS-108	10/21/20	0.0063 mg/L			
109	Room 2103 Island Sink	MS-109	10/21/20	0.0041 mg/L			
110	Room 2103 Island Sink	MS-110	10/21/20	0.011 mg/L			
111	Room 2103 Island Sink	MS-111	10/21/20	0.0063 mg/L			
112	Room 2103 Island Sink	MS-112	10/21/20	0.0071 mg/L			
113	Room 2103 Hand Sink (teacher)	MS-113	10/21/20	0.011 mg/L			
114	Room 2103/2102 Storage Hand Sink	MS-114	10/21/20	0.023 mg/L	Posted Non-Potable		
115	Room 2102 Hand Sink (teacher)	MS-115	10/21/20	0.025 mg/L	Posted Non-Potable		
116	Room 2102 Island Sink	MS-116	10/21/20	0.042 mg/L	Posted Non-Potable		
117	Room 2102 Island Sink	MS-117	10/21/20	0.0072 mg/L			

## Middle School

118	Room 2102 Island Sink	MS-118	10/21/20	0.0082 mg/L
119	Room 2102 Island Sink	MS-119	10/21/20	0.0083 mg/L
120	Room 2102 Island Sink	MS-120	10/21/20	0.0068 mg/L
121	Room 2102 Island Sink	MS-121	10/21/20	0.006 mg/L
122	2nd Floor Science Wing Water Fountain	MS-122	10/21/20	<0.0010 mg/L
123	Pod A 2nd Floor Water Fountain	MS-123	10/21/20	<0.0010 mg/L
124	Pod A Boys Bath Hand Sink Right	MS-124	10/21/20	<0.0010 mg/L
125	Pod A Boys Bath Hand Sink Left	MS-125	10/21/20	0.0036 mg/L
126	Pod A Girls Bath Hand Sink Left	MS-126	10/21/20	<0.0010 mg/L
127	Pod A Girls Bath Hand Sink Right	MS-127	10/21/20	0.0033 mg/L
128	Pod A 2nd Floor Custodial Sink	MS-128	10/21/20	0.010 mg/L
129	Room 2007 Hand Sink Right	MS-129	10/21/20	0.011 mg/L
130	Room 2007 Hand Sink Left	MS-130	10/21/20	0.028 mg/L Posted Non-Potable
131	Room 2008 Hand Sink Left	MS-131	10/21/20	0.0011 mg/L
132	Room 2008 Hand Sink Right	MS-132	10/21/20	0.0026 mg/L
133	Pod C Outside Hose Bib	MS-133	10/21/20	0.0042 mg/L

# High School

<u>Location Number</u>	<u>Description</u>	<u>Sample #</u>	<u>Sample Date</u>	<u>Results</u>	<u>Remediation</u>	<u>Retest Sample #</u>	<u>Retest Date</u>	<u>Retest Results</u>
1	Room 1106 Hand Sink Right	HS-1	10/22/20	0.014 mg/L				
2	Room 1106 Hand Sink Center	HS-2	10/22/20	0.012 mg/L				
3	Room 1106 Hand Sink Left	HS-3	10/22/20	0.015 mg/L	Posted Non-Potable			
4	Room 1105 Hand Sink Right	HS-4	10/22/20	<0.0010 mg/L				
5	Room 1105 Hand Sink Left	HS-5	10/22/20	0.0010 mg/L				
6	Maintenance Break Room Sink	HS-6	10/22/20	<0.0010 mg/L				
7	Maintenance Bath Hand Sink	HS-7	10/22/20	<0.0010 mg/L				
8	Faculty Mens Bath Hand Sink	HS-8	10/22/20	0.0011 mg/L				
9	Faculty Womens Bath Hand Sink	HS-9	10/22/20	<0.0010 mg/L				
10	Faculty Room Hand Sink	HS-10	10/22/20	<0.0010 mg/L				
11	Maintenance Hall Water Fountain	HS-11	10/22/20	<0.0010 mg/L				
12	Main Hall Custodial Sink	HS-12	10/22/20	0.0015 mg/L				
13	Girls Locker Hand Sink Left	HS-13	10/22/20	Not functioning, Resample when repaired				
14	Girls Locker Hand Sink Center	HS-14	10/22/20	0.0013 mg/L				
15	Girls Locker Hand Sink Right	HS-15	10/22/20	0.0036 mg/L				
16	Girls Locker Water Fountain	HS-16	10/22/20	<0.0010 mg/L				
17	PE Office Bath Hand Sink	HS-17	10/22/20	0.0013 mg/L				
18	Athletic Hall Custodial Sink	HS-18	10/22/20	0.0018 mg/L				
19	Athletic Hall Water Fountain Right	HS-19	10/22/20	<0.0010 mg/L				
20	Athletic Hall Water Fountain Left	HS-20	10/22/20	<0.0010 mg/L				
21	Mens Bath Hand Sink Left	HS-21	10/22/20	0.0011 mg/L				
22	Mens Bath Hand Sink Center	HS-22	10/22/20	<0.0010 mg/L				
23	Mens Bath Hand Sink Right	HS-23	10/22/20	<0.0010 mg/L				
24	Womens Bath Hand Sink Right	HS-24	10/22/20	0.0018 mg/L				
25	Womens Bath Hand Sink Center	HS-25	10/22/20	0.0010 mg/L				
26	Womens Bath Hand Sink Left	HS-26	10/22/20	0.0016 mg/L				
27	Concession Sink	HS-27	10/22/20	0.0059 mg/L				
28	Trainer Office Hand Sink	HS-28	10/22/20	0.0012 mg/L				
29	Trainer Office Ice Machine	HS-29	10/22/20	Couldn't get a sample, Resample when doing remediation samples				
30	PE Office Bath Hand Sink Left	HS-30	10/22/20	<0.0010 mg/L				
31	PE Office Bath Hand Sink Right	HS-31	10/22/20	0.0015 mg/L				
32	Boys Locker Bath Hand Sink Left	HS-32	10/22/20	<0.0010 mg/L				
33	Boys Locker Bath Hand Sink Center	HS-33	10/22/20	<0.0010 mg/L				
34	Boys Locker Bath Hand Sink Right	HS-34	10/22/20	0.0024 mg/L				
35	Boys Locker Water Fountain	HS-35	10/22/20	<0.0010 mg/L				
36	Boys Locker Team Room Water Fountain	HS-36	10/22/20	<0.0010 mg/L				
37	Room 1026 Hand Sink	HS-37	10/22/20	0.0017 mg/L				
38	Room 1026 Bath Hand Sink	HS-38	10/22/20	<0.0010 mg/L				
39	Foreign Language Hall Water Fountain	HS-39	10/22/20	0.0015 mg/L				
40	Library Hall Custodial Sink	HS-40	10/22/20	<0.0010 mg/L				
41	Library Hall Womens Bath Hand Sink	HS-41	10/22/20	<0.0010 mg/L				
42	Library Hall Mens Bath Hand Sink	HS-42	10/22/20	<0.0010 mg/L				
43	Library Bath Hand Sink	HS-43	10/22/20	<0.0010 mg/L				
44	Library Hand Sink	HS-44	10/22/20	<0.0010 mg/L				
45	Library Hall Water Fountain	HS-45	10/22/20	0.0022 mg/L				
46	Womens Bath Hand Sink Left	HS-46	10/22/20	<0.0010 mg/L				
47	Womens Bath Hand Sink Right	HS-47	10/22/20	<0.0010 mg/L				
48	Mens Bath Hand Sink Left	HS-48	10/22/20	<0.0010 mg/L				
49	Mens Bath Hand Sink Right	HS-49	10/22/20	<0.0010 mg/L				
50	Senior Hall Water Fountain	HS-50	10/22/20	0.0014 mg/L				
51	Nurses Office Bath Hand Sink	HS-51	10/22/20	<0.0010 mg/L				
52	Nurses Office Sink	HS-52	10/22/20	<0.0010 mg/L				
53	Principal Office Bath Hand Sink	HS-53	10/22/20	0.0078 mg/L				
54	Womens Bath Hand Sink Left	HS-54	10/22/20	0.0052 mg/L				
55	Womens Bath Hand Sink Center	HS-55	10/22/20	0.0048 mg/L				
56	Womens Bath Hand Sink Right	HS-56	10/22/20	0.011 mg/L				
57	Main Office Water Fountain Left	HS-57	10/22/20	<0.0010 mg/L				
58	Main Office Water Fountain Right	HS-58	10/22/20	<0.0010 mg/L				
59	Mens Bath Hand Sink Right	HS-59	10/22/20	0.0011 mg/L				

# High School

60	Mens Bath Hand Sink Center	HS-60	10/22/20	<0.0010 mg/L	
61	Mens Bath Hand Sink Left	HS-61	10/22/20	0.0084 mg/L	
62	Cafeteria Water Fountain Right	HS-62	10/22/20	<0.0010 mg/L	
63	Cafeteria Water Fountain Left	HS-63	10/22/20	<0.0010 mg/L	
64	Music Hall Water Fountain	HS-64	10/22/20	Not functioning, Resample when repaired	
65	Music Womens Bath Hand Sink Left	HS-65	10/22/20	<0.0010 mg/L	
66	Music Womens Bath Hand Sink Right	HS-66	10/22/20	<0.0010 mg/L	
67	Music Mens Bath Hand Sink Right	HS-67	10/22/20	<0.0010 mg/L	
68	Music Mens Bath Hand Sink Left	HS-68	10/22/20	<0.0010 mg/L	
69	Music Storage Hand Sink	HS-69	10/22/20	0.0041 mg/L	
70	Kitchen Ice Machine	HS-70	10/22/20	0.0062 mg/L	
71	Kitchen Wash Sink Left	HS-71	10/22/20	0.0020 mg/L	
72	Kitchen Wash Sink Right	HS-72	10/22/20	0.0056 mg/L	
73	Kitchen Hand Sink	HS-73	10/22/20	0.0016 mg/L	
74	Kitchen Island Sink	HS-74	10/22/20	0.0018 mg/L	
75	Kitchen Cook Water Supply	HS-75	10/22/20	0.0091 mg/L	
76	Kitchen Wash Sink	HS-76	10/22/20	<0.0010 mg/L	
77	Kitchen Custodial Sink	HS-77	10/22/20	<0.0010 mg/L	
78	Kitchen Bath Hand Sink	HS-78	10/22/20	0.0039 mg/L	
79	Serving Line Coffee Maker	HS-79	10/22/20	<0.0010 mg/L	
80	Room 2032 Teacher Sink	HS-80	10/22/20	0.0027 mg/L	
81	Room 2030 Teacher Sink	HS-81	10/22/20	0.0032 mg/L	
82	Math Hall Water Fountain	HS-82	10/22/20	<0.0010 mg/L	
83	Room 2031 Hand Sink (Window)	HS-83	10/22/20	0.0012 mg/L	
84	Room 2031 Island Sink (South)	HS-84	10/22/20	0.0096 mg/L	
85	Room 2031 Island Sink (North)	HS-85	10/22/20	0.012 mg/L	
86	Room 2031 Island Sink (South)	HS-86	10/22/20	0.011 mg/L	
87	Room 2031 Island Sink (North)	HS-87	10/22/20	0.013 mg/L	
88	Room 2031 Island Sink (South)	HS-88	10/22/20	0.0099 mg/L	
89	Room 2031 Island Sink (North)	HS-89	10/22/20	0.011 mg/L	
90	Room 2031 Island Sink (South)	HS-90	10/22/20	0.0082 mg/L	
91	Room 2031 Island Sink (North)	HS-91	10/22/20	0.022 mg/L	Posted Non-Potable
92	Room 2031 Island Sink (South)	HS-92	10/22/20	0.0020 mg/L	
93	Room 2031 Island Sink (North)	HS-93	10/22/20	0.011 mg/L	
94	Room 2031 Island Sink (South)	HS-94	10/22/20	0.013 mg/L	
95	Room 2031 Island Sink (North)	HS-95	10/22/20	0.011 mg/L	
96	Room 2029 Hand Sink (Window)	HS-96	10/22/20	0.0030 mg/L	
97	Room 2029 Island Sink (South)	HS-97	10/22/20	0.0079 mg/L	
98	Room 2029 Island Sink (North)	HS-98	10/22/20	0.011 mg/L	
99	Room 2029 Island Sink (South)	HS-99	10/22/20	0.0090 mg/L	
100	Room 2029 Island Sink (North)	HS-100	10/22/20	0.0083 mg/L	
101	Room 2029 Island Sink (South)	HS-101	10/22/20	0.013 mg/L	
102	Room 2029 Island Sink (North)	H2-102	10/22/20	0.016 mg/L	Posted Non-Potable
103	Room 2029 Island Sink (South)	HS-103	10/22/20	0.0091 mg/L	
104	Room 2029 Island Sink (North)	HS-104	10/22/20	0.012 mg/L	
105	Room 2029 Island Sink (South)	H2-105	10/22/20	0.0087 mg/L	
106	Room 2029 Island Sink (North)	HS-106	10/22/20	0.0073 mg/L	
107	Room 2029 Island Sink (South)	HS-107	10/22/20	0.011 mg/L	
108	Room 2029 Island Sink (North)	HS-108	10/22/20	0.0082 mg/L	
109	Room 2029/2031 Prep Sink	HS-109	10/22/20	0.0035 mg/L	
110	Art/Business Hall Water Fountain	HS-110	10/22/20	<0.0010 mg/L	
111	Art/Business Hall Custodial Sink	HS-111	10/22/20	0.0018 mg/L	
112	Room 2017 Island Sink Window	HS-112	10/22/20	0.0061 mg/L	
113	Room 2017 Island Sink Hall	HS-113	10/22/20	0.0077 mg/L	
114	Room 2015 Island Sink Window	HS-114	10/22/20	0.0045 mg/L	
115	Room 2015 Island Sink Hall	HS-115	10/22/20	<0.0010 mg/L	
116	Room 2015 Sink	HS-116	10/22/20	0.0046 mg/L	
117	Dark Room Sink Right	HS-117	10/22/20	0.0035 mg/L	
118	Dark Room Sink Center	HS-118	10/22/20	0.020 mg/L	Posted Non-Potable
119	Dark Room Sink Left	HS-119	10/22/20	0.0036 mg/L	

# High School

120	Sophomore Hall Water Fountain	HS-120	10/22/20	0.0036 mg/L	
121	2nd Floor Girls Bath Hand Sink Left	HS-121	10/22/20	0.0020 mg/L	
122	2nd Floor Girls Bath Hand Sink Center	HS-122	10/22/20	0.0086 mg/L	
123	2nd Floor Girls Bath Hand Sink Right	HS-123	10/22/20	<0.0010 mg/L	
124	2nd Floor Bath Water Fountain Left	HS-124	10/22/20	<0.0010 mg/L	
125	2nd Floor Bath Water Fountain Right	HS-125	10/22/20	<0.0010 mg/L	
126	2nd Floor Boys Bath Hand Sink Right	HS-126	10/22/20	0.0036 mg/L	
127	2nd Floor Boys Bath Hand Sink Center	HS-127	10/22/20	0.0073 mg/L	
128	2nd Floor Boys Bath Hand Sink Left	HS-128	10/22/20	0.013 mg/L	
129	2nd Floor Womens Faculty Bath Sink	HS-129	10/22/20	0.0014 mg/L	
130	2nd Floor Mens Faculty Bath Sink	HS-130	10/22/20	0.0015 mg/L	
131	2nd Floor Music Hall Water Fountain	HS-131	10/22/20	<0.0010 mg/L	
132	Room 2110 Teacher Sink	HS-132	10/22/20	0.032 mg/L	Posted Non-Potable
133	Room 2110 East Hand Sink	HS-133	10/22/20	0.0019 mg/L	
134	Room 2110 Island Sink East	HS-134	10/22/20	0.0078 mg/L	
135	Room 2110 Island Sink West	HS-135	10/22/20	0.021 mg/L	Posted Non-Potable
136	Room 2110 West Sink Right	HS-136	10/22/20	0.0035 mg/L	
137	Room 2110 West Sink Left	HS-137	10/22/20	0.0041 mg/L	
138	Room 2110/2109 South Sink	HS-138	10/22/20	0.19 mg/L	Posted Non-Potable
139	Room 2110/2109 East Sink	HS-139	10/22/20	0.31 mg/L	Posted Non-Potable
140	Room 2108 East Sink Right	HS-140	10/22/20	0.013 mg/L	
141	Room 2108 East Sink Left	HS-141	10/22/20	0.0033 mg/L	
142	Room 2108 Island Sink East	HS-142	10/22/20	Removed from service	
143	Room 2108 Island Sink West	HS-143	10/22/20	Removed from service	
144	Room 2108 West Sink	HS-144	10/22/20	0.0052 mg/L	
145	Room 2108 Teacher Sink	HS-145	10/22/20	Removed from service	
146	Technology Hall Water Fountain	HS-146	10/22/20	<0.0010 mg/L	
147	Room 2104 Window Sink Left	HS-147	10/22/20	Removed from service	
148	Room 2104 Window Sink Left/Center	HS-148	10/22/20	0.0033 mg/L	
149	Room 2104 Window Sink Right/Center	HS-149	10/22/20	0.0010 mg/L	
150	Room 2104 Window Sink Right	HS-150	10/22/20	Removed from service	
151	Science Hall Custodial Closet	HS-151	10/22/20	0.0049 mg/L	
152	Room 2103 Teacher Sink	HS-152	10/22/20	0.0031 mg/L	
153	Room 2103/2102 Sink South	HS-153	10/22/20	0.021 mg/L	Posted Non-Potable
154	Room 2103/2102 Sink East	HS-154	10/22/20	0.19 mg/L	Posted Non-Potable
155	Room 2101 Teacher Sink	HS-155	10/22/20	Removed from service	
156	Room 2101 West Sink	HS-156	10/22/20	0.0034 mg/L	
157	Room 2101 Island Sink West	HS-157	10/22/20	Removed from service	
158	Room 2101 Island Sink East	HS-158	10/22/20	Removed from service	
159	Room 2101 East Sink Left	HS-159	10/22/20	0.0060 mg/L	
160	Room 2101 East Sink Right	HS-160	10/22/20	0.0090 mg/L	
161	Concession Hose Bib	HS-161	10/22/20	<0.0010 mg/L	
162	Concession Stand Wash Sink	HS-162	10/22/20	0.0024 mg/L	
163	Concession Mens Bath Hand Sink (Right)	HS-163	10/22/20	0.015 mg/L	Posted Non-Potable
164	Concession Mens Bath Hand Sink (Left)	HS-164	10/22/20	0.0062 mg/L	
165	Concession Womens Bath Hand Sink (Right)	HS-165	10/22/20	<0.0010 mg/L	
166	Concession Womens Bath Hand Sink (Left)	HS-166	10/22/20	<0.0010 mg/L	

# Lake Street

Location Number	Description	Sample #	Sample Date	Results	Remediation	Retest Sample #	Retest Date	Retest Results
1	Gym Hall Water Fountain Left	LS-1	10/27/20	<0.0010 mg/L				
2	Gym Hall Water Fountain Right	LS-2	10/27/20	<0.0010 mg/L				
3	Boys Gang Bath Hand Sink Left	LS-3	10/27/20	0.0028 mg/L				
4	Boys Gang Bath Hand Sink Center	LS-4	10/27/20	0.0026 mg/L				
5	Boys Gang Bath Hand Sink Right	LS-5	10/27/20	0.0032 mg/L				
6	Girls Gang Bath Hand Sink Left	LS-6	10/27/20	0.0039 mg/L				
7	Girls Gang Bath Hand Sink Center	LS-7	10/27/20	0.0040 mg/L				
8	Girls Gang Bath Hand Sink Right	LS-8	10/27/20	0.0023 mg/L				
9	Boys Locker Water Fountain	LS-9	10/27/20	Removed from service in 2016				
10	Boys Locker Bath Hand Sink Right	LS-10	10/27/20	0.027 mg/L	Posted Non-Potable			
11	Boys Locker Bath Hand Sink Left	LS-11	10/27/20	0.029 mg/L	Posted Non-Potable			
12	Girls Locker Water Fountain	LS-12	10/27/20	Removed from service in 2016				
13	Girls Locker Bath Hand Sink Left	LS-13	10/27/20	0.013 mg/L				
14	Girls Locker Bath Hand Sink Right	LS-14	10/27/20	Removed from service in 2016				
15	Girls Locker Custodial Sink	LS-15	10/27/20	0.31 mg/L	Posted Non-Potable			
16	Girls PE Office Hand Sink	LS-16	10/27/20	0.010 mg/L				
17	Boys PE Office Hand Sink	LS-17	10/27/20	0.0087 mg/L				
18	Room 129 Hand Sink Left	LS-18	10/27/20	0.0011 mg/L				
19	Room 129 Hand Sink Right	LS-19	10/27/20	<0.0010 mg/L				
20	Room 129 Water Fountain	LS-20	10/27/20	0.0045 mg/L				
21	Room 125 Hand Sink Right	LS-21	10/27/20	0.0021 mg/L				
22	Room 125 Hand Sink Left	LS-22	10/27/20	<0.0010 mg/L				
23	Room 125 Water Fountain	LS-23	10/27/20	0.016 mg/L	Shut off and Remove from Service			
24	Room 123 Hand Sink Left	LS-24	10/27/20	0.0014 mg/L				
25	Room 123 Hand Sink Right	LS-25	10/27/20	0.0027 mg/L				
26	Room 123 Water Fountain	LS-26	10/27/20	<0.0010 mg/L				
27	Room 119 Hand Sink Right	LS-27	10/27/20	0.0065 mg/L				
28	Room 119 Hand Sink Left	LS-28	10/27/20	<0.0010 mg/L				
29	Room 119 Water Fountain	LS-29	10/27/20	<0.0010 mg/L				
30	Room 115 Hand Sink	LS-30	10/27/20	<0.0010 mg/L				
31	Room 115 Water Fountain	LS-31	10/27/20	<0.0010 mg/L				
32	Room 112/113 Bath Hand Sink	LS-32	10/27/20	<0.0010 mg/L				
33	Room 107 Hand Sink	LS-33	10/27/20	0.0034 mg/L				
34	Room 107 Water Fountain	LS-34	10/27/20	Not functioning	Shut off and Remove from Service			
35	Room 109 Hand Sink	LS-35	10/27/20	0.0013 mg/L				
36	Room 109 Water Fountain	LS-36	10/27/20	Not functioning	Shut off and Remove from Service			
37	Library Office 137 Hand Sink	LS-37	10/27/20	0.032 mg/L	Posted Non-Potable			
38	1st Floor Custodial Sink	LS-38	10/27/20	0.0062 mg/L				
39	Faculty Room Hand Sink	LS-39	10/27/20	0.0037 mg/L				
40	Faculty Room Bath Hand Sink	LS-40	10/27/20	0.0021 mg/L				
41	Main Office Hallway Water Fountain	LS-41	10/27/20	0.0034 mg/L				
42	Room 105 Hand Sink	LS-42	10/27/20	<0.0010 mg/L				
43	Room 105 Water Fountain	LS-43	10/27/20	<0.0010 mg/L				
44	Room 103 Hand Sink	LS-44	10/27/20	<0.0010 mg/L				
45	Room 103 Water Fountain	LS-45	10/27/20	<0.0010 mg/L				
46	Nurses Office Bath Hand Sink	LS-46	10/27/20	0.017 mg/L	Posted Non-Potable, Replace fixture/supply lines/shutoff, Retest			
47	Nurses Office Hand Sink	LS-47	10/27/20	0.0083 mg/L				
48	Main Office Hand Sink	LS-48	10/27/20	0.0010 mg/L				
49	Art Room 101 Right Hand Sink	LS-49	10/27/20	Not functioning	Posted Non-Potable, Repair Fixture and Test			
50	Art Room 101 Left Hand Sink	LS-50	10/27/20	Not functioning	Posted Non-Potable, Repair Fixture and Test			
51	Main Office Bath Hand Sink	LS-51	10/27/20	0.0022 mg/L				
52	Room 133 Hand Sink	LS-52	10/27/20	0.0023 mg/L				
53	Room 133 Water Fountain	LS-53	10/27/20	0.0052 mg/L				
54	Room 135 Hand Sink	LS-54	10/27/20	0.0018 mg/L				
55	Room 135 Water Fountain	LS-55	10/27/20	<0.0010 mg/L				
56	Room 215 Water Fountain	LS-56	10/27/20	<0.0010 mg/L				
57	Room 215 Hand Sink	LS-57	10/27/20	<0.0010 mg/L				
58	Room 218 Hand Sink	LS-58	10/27/20	<0.0010 mg/L				
59	Room 218 Water Fountain	LS-59	10/27/20	<0.0010 mg/L				
60	Room 213 Water Fountain	LS-60	10/27/20	<0.0010 mg/L				
61	Room 213 Hand Sink	LS-61	10/27/20	<0.0010 mg/L				
62	Room 207 Hand Sink	LS-62	10/27/20	<0.0010 mg/L				
63	Room 207 Water Fountain	LS-63	10/27/20	Not functioning	Shut off and Remove from Service			
64	Room 201 Water Fountain	LS-64	10/27/20	<0.0010 mg/L				
65	Room 201 Hand Sink	LS-65	10/27/20	<0.0010 mg/L				
66	Room 203 Hand Sink	LS-66	10/27/20	<0.0010 mg/L				
67	Room 203 Water Fountain	LS-67	10/27/20	<0.0010 mg/L				
68	Room 205 Hand Sink	LS-68	10/27/20	<0.0010 mg/L				
69	Room 205 Water Fountain	LS-69	10/27/20	<0.0010 mg/L				
70	2nd Floor Custodial Sink	LS-70	10/27/20	0.012 mg/L				
71	Room 211 Water Fountain	LS-71	10/27/20	<0.0010 mg/L				
72	Room 211 Hand Sink	LS-72	10/27/20	<0.0010 mg/L				
73	Basement Bath Hand Sink	LS-73	10/27/20	0.020 mg/L	Posted Non-Potable, Replace fixture/supply lines/shutoff, Retest			
74	Cafeteria Water Fountain	LS-74	10/27/20	<0.0010 mg/L				
75	Kitchen Sink Left West Wall	LS-75	10/27/20	0.026 mg/L	Temporarily removed from service, Replace fixture/supply lines/shutoff, Re	LS2-75	3/2/21	0.0074 mg/L
76	Kitchen Sink Center West Wall	LS-76	10/27/20	0.018 mg/L	Temporarily removed from service, Replace fixture/supply lines/shutoff, Re	LS2-76	3/2/21	0.0041 mg/L
77	Kitchen Sink Right West Wall	LS-77	10/27/20	0.044 mg/L	Temporarily removed from service, Replace fixture/supply lines/shutoff, Re	LS2-77	3/2/21	0.0060 mg/L
78	Basement Custodial Sink	LS-78	10/27/20	0.0032 mg/L				
79	Basement Hallway Water Fountain	LS-79	10/27/20	Not functioning	Shut off and Remove from Service			
80	Room 102 Bath Sink	LS-80	10/27/20	0.0014 mg/L				
81	ESM Hand Sink	LS-81	3/2/21	0.0039 mg/L				
82	ESM Prep Sink	LS-82						